



UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300



In-Situ Test Report

Relevant Standards
UL1598-2008

Prepared For
TechBrite LLC
David Brown
1000 Kieley Pl
Cincinnati, OH 45217

Catalog Number
V874SS1B50GXXXX

Test Number
1175749

Test Date

2015-11-25

Prepared By

Derek Smarr, Technician

Approved By

Carissa Samonte-cam, Project Handler

The results contained in this report pertain only to the tested sample.

This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.

This report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government.




UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300



Luminaire Description: White plastic housing, frosted stepped plastic lens enclosure
Catalog Number: V874SS1B50GXXXX
Lamp: 224 white LEDs
Mounting: Pendant
Ballast/Driver: One Everline D21CC80UNVTW-D

Luminaire



Summary of Results

LED Temperature: 73.3 °C
Driver Temperature: 46.1 °C
Maximum LED Current: 0.1140 A

Test Conditions

Test Temperature: 23.3 °C
Voltage: 119.9 VAC
Frequency: 60 Hz


Temperatures are offset to an ambient
temperature of 25°C as described in
UL1598-2008.



UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300



LED Temperature Location



Driver Temperature Location

